

AMENDMENT OF SOLICITATION/CONTRACT (AGREEMENT)

SECTION I

Instructions to Offerors --- Amendment of Solicitation. The following instructions apply unless specified otherwise in an AAFES letter accompanying this amendment.

a. Offerors must acknowledge receipt of this amendment prior to the hour and date specified for receipt of proposals in the original solicitation, or the hour and date specified in this amendment if such has been amended. Offeror must acknowledge by one of the following means:

(1) By signing and returning all except one copy of this amendment;

(2) By acknowledging receipt of this amendment on each copy of the proposal submitted;

(3) By separate letter or telegram which includes a reference to the solicitation and amendment number.

b. Proposals must be based upon and refer to the solicitation as amended. Unless an acknowledgment of this amendment is received by the Contracting Officer before the hour and date specified for receipt of proposals, Offeror=s proposal may be considered nonresponsive.

c. If you desire to revise a proposal previously submitted, such revision must be received prior to the hour and date specified for receipt of proposals inclosed in a sealed envelope addressed to the issuing office, with the name and address of offeror and the solicitation number on the face of the envelope. Telegraphic proposals will not be considered unless authorized by the solicitation; however, proposals may be modified by telegraphic notice provided such notice is received prior to the time set for receipt of proposals. Telegraphic modifications should not reveal the amount of the original or of the revised proposal.

SECTION II

Instructions to Contractor --- Amendment of Contract.

Unless otherwise instructed, all except one copy of this Amendment are to be executed by a person authorized to bind the firm contractually and returned to the Contracting Officer. The effective date will be the date the amendment is signed in block 6 by the Contracting Officer or the date(s) indicated in block 4, whichever is later.

Solicitation #AAFES-REZC-04-005-09-079
Attachment #1 to
Amendment #4

QUESTIONS AND ANSWERS

Question 1: The owner supplied fueling components do not show a location as to where they will be mounted and get power from?

Answer 1: The AFFES furnished items shown in detail 1/GE1 are noted to be located in the office and powered from the "PPC". The exact location in the office will need to be field verified with AAFES.

Question 2: Is it possible to substitute another manufacturer for the fueling control cabinet?

Answer 2: No. The Power Integrity System is required.

Question 3: Is it going to be required for any special grounding or bonding for the canopy, fuel dispenser and fuel tanks?

Answer 3: There is no "special" bonding or grounding required for the canopy, dispensers or tanks, outside of the bonding and grounding required by the National Electrical Code.

Question 4: Reference is made to a Fire Alarm but nothing clear other than interconnecting with the Stores system. The conduit & wire can be supplied and installed. Will the base fire alarm monitoring company make the final connection?

Answer 4: The emergency shutdown system must be interfaced with the building fire alarm system as indicated on GE1. The fire alarm system is presumed to be existing or at least provided outside the fueling system contract. The fueling contractor is required to connect to the existing fire alarm control panel. For the purposes of bidding it should be assumed that the necessary contacts and fire alarm initiation terminals are existing.