

SECTION I

Instructions to Offerors -- Amendment of Solicitation. The following instructions apply unless specified otherwise in an AAFES letter accompanying this amendment.

a. Offerors must acknowledge receipt of this amendment prior to the hour and date specified for receipt of proposals in the original solicitation, or the hour and date specified in this amendment if such has been amended. Offeror must acknowledge by one of the following means:

- (1) By signing and returning all except one copy of this amendment.
- (2) By acknowledging receipt of this amendment on each copy of the proposal submitted;
- (3) By separate letter or telegram which includes a reference to the solicitation and amendment number.

b. Proposals must be based upon and refer to the solicitation as amended. Unless an acknowledgment of this amendment is received by the contracting officer before the hour and date specified for receipt of proposals, offeror's proposal may be considered nonresponsive.

c. If you desire to revise a proposal previously submitted, such revision must be received prior to the hour and date specified for receipt of proposals enclosed in a sealed envelope addressed to the issuing office, with the name and address of the offeror and the solicitation number on the face of the envelope. Telegraphic proposals will not be considered unless authorized by the solicitation; however, proposals may be modified by telegraphic notice provided such notice is received prior to the time set for receipt of proposals. Telegraphic modifications should not reveal the amount of the original or of the revised proposal.

SECTION II

Instructions to Contractor -- Amendment of Contract.

Unless otherwise instructed, all except one copy of this amendment are to be executed by the person authorized to bind the firm contractually and returned to the contracting officer. The effective date will be the date the amendment is signed in block 6 by the contracting officer or the date(s) indicated in block 4, whichever is later.

Question #1: Section 04300 – Please clarify that Unit Masonry System does not require an integral color architectural split face masonry unit thus implying the units are paint grade units.

Answer #1: Unit Masonry for the building to be Architectural split face masonry units with integral color. Color to be selected by the Architect at a later date of submittal.

Question #2: Section 09900 – Please clarify that painting provides a paint schedule for interior and exterior concrete block requiring latex paint thus implying the masonry units are paint grade units.

Answer #2: The unit masonry is to be integral color not painted. Section 09900 is a generic guideline in the painting of different material surfaces.

Question #3: Section 07190 – Please clarify that the water repellants require unit masonry systems to be coated with the specified water repellent.

Answer #3: The water repellants as specified will be used in the open wand wash bays on the Architectural masonry units. (Color range will be in the brown/beige color palette.)

- a. Architectural split face masonry units with integral color will be used. (Color range will be in the brown/beige color palette.)
- b. Section 09900 Painting will not be used for the block called out above. Section 07190 Water Repellents will be used for the block called out above.

Question #4: Please clarify detail 5/E3.0 on drawing number E3.0 which makes reference to route (2) 2” conduits to existing manhole. This manhole is NOT shown on site plan as referenced. What is the location of said manhole?

Answer #4: Reference detail number 5/E3.0. There is currently no existing communications manhole to run the conduits to. However, the Contractor shall run the (2) 2” conduits as specified from the equipment room where shown to 10’ -0” outside the East paved drive/curb and stub up, cap and mark for future communications tie-in.

Question #5: The same detail as referenced above shows a “gas protected terminal” and a “terminal strip.” Who is responsible to provide and install said equipment?

Answer #5: The Contractor is to provide and install the called out and shown terminal strip and gas protector strip.

Question #6: Who is responsible for the building permit and any tap fees for the Fort Bragg Car Wash? Do you know where I could find a fee schedule?

Answer #6: There are no building permit fees to be paid on the Ft. Bragg Post for the project. Drawing C3.0 "General Notes" states that all utilities installed with associated fees will be paid by AAFES to Ft. Bragg's private utility services company (ONUS).

Question #7: What is the physical address of the Ft. Bragg Carwash?

Answer #7: The address is unknown at this time.

Question #8: Do over-night FedEx packages need to be sent to 3911 S. Walton Walker Blvd, Dallas, TX 75236?

Answer #8: Yes.