

SECTION I

Instructions to Offerors -- Amendment of Solicitation. The following instructions apply unless specified otherwise in an AAFES letter accompanying this amendment.

a. Offerors must acknowledge receipt of this amendment prior to the hour and date specified for receipt of proposals in the original solicitation, or the hour and date specified in this amendment if such has been amended. Offeror must acknowledge by one of the following means:

- (1) By signing and returning all except one copy of this amendment.
- (2) By acknowledging receipt of this amendment on each copy of the proposal submitted;
- (3) By separate letter or telegram which includes a reference to the solicitation and amendment number.

b. Proposals must be based upon and refer to the solicitation as amended. Unless an acknowledgment of this amendment is received by the contracting officer before the hour and date specified for receipt of proposals, offeror's proposal may be considered nonresponsive.

c. If you desire to revise a proposal previously submitted, such revision must be received prior to the hour and date specified for receipt of proposals enclosed in a sealed envelope addressed to the issuing office, with the name and address of the offeror and the solicitation number on the face of the envelope. Telegraphic proposals will not be considered unless authorized by the solicitation; however, proposals may be modified by telegraphic notice provided such notice is received prior to the time set for receipt of proposals. Telegraphic modifications should not reveal the amount of the original or of the revised proposal.

SECTION II

Instructions to Contractor -- Amendment of Contract.

Unless otherwise instructed, all except one copy of this amendment are to be executed by the person authorized to bind the firm contractually and returned to the contracting officer. The effective date will be the date the amendment is signed in block 6 by the contracting officer or the date(s) indicated in block 4, whichever is later.

Question #1: Drawing number C4.0 depicts an Electrical Service Disconnect mounted on the building structure. This disconnect is NOT shown on Electrical Service Diagram detail 1/E3.0 on sheet E3.0. Is this Electrical Disconnect required?

Answer #1: Drawing SE1.0 (C4.0) depicts and calls out for an electrical disconnect and it is required. Drawing detail 1/E3.0 "Electrical Service Diagram" does note for an exterior service disconnect.

Question #2: Drawing number C4.0 Electrical Service Note requires contractor to be responsible for "coordination and payment" to Sandhill Utility Services for Electrical Services for this project. In the past, the government has paid the private utility company directly. Is the contractor responsible to pay utility fees for this project?

Answer #2: Contractor is only responsible to pay Sandhill Utility Services for Electrical only. All other utilities will be paid by AAFES as stated on drawing C3.0 under "General Notes."

Question #3: Note on drawing number SE1.0 reads: "Area light provided by utility. Recommended 400 watt, metal halide, NEMA type III distribution and 30' mounting height, typical (6) places." Detail 6/C5.0 shows 'Area Light Concrete Foundation Detail'. Does the utility contractor provide light pole only or light pole, pole base and electrical conduit and wiring?

Answer #3: Contractor is to provide light pole concrete bases as detailed on drawing 6/C5.0, as well as electrical conduits and electrical runs. The Post will provide light pole anchor bolts, light poles, light fixtures and final installation.

Question #4: Where is the Shoppette/Kiosk located? Reference item #20 "Code-A-Wash" junction box noted on the Car Wash Equipment Schedule on Drawing E2.0.

Answer #4: The reference note on drawing E2.0 for item #20 which states "to be run to Shoppette/Kiosk" is an error. This is not required in conjunction with this project.