

AMENDMENT OF SOLICITATION/CONTRACT (AGREEMENT)

SECTION I

Instructions to Offerors --- Amendment of Solicitation. The following instructions apply unless specified otherwise in an AAFES letter accompanying this amendment.

a. Offerors must acknowledge receipt of this amendment prior to the hour and date specified for receipt of proposals in the original solicitation, or the hour and date specified in this amendment if such has been amended. Offeror must acknowledge by one of the following means:

(1) By signing and returning all except one copy of this amendment;

(2) By acknowledging receipt of this amendment on each copy of the proposal submitted;

(3) By separate letter or telegram which includes a reference to the solicitation and amendment number.

b. Proposals must be based upon and refer to the solicitation as amended. Unless an acknowledgment of this amendment is received by the Contracting Officer before the hour and date specified for receipt of proposals, Offeror=s proposal may be considered nonresponsive.

c. If you desire to revise a proposal previously submitted, such revision must be received prior to the hour and date specified for receipt of proposals inclosed in a sealed envelope addressed to the issuing office, with the name and address of offeror and the solicitation number on the face of the envelope. Telegraphic proposals will not be considered unless authorized by the solicitation; however, proposals may be modified by telegraphic notice provided such notice is received prior to the time set for receipt of proposals. Telegraphic modifications should not reveal the amount of the original or of the revised proposal.

SECTION II

Instructions to Contractor --- Amendment of Contract.

Unless otherwise instructed, all except one copy of this Amendment are to be executed by a person authorized to bind the firm contractually and returned to the Contracting Officer. The effective date will be the date the amendment is signed in block 6 by the Contracting Officer or the date(s) indicated in block 4, whichever is later.

QUESTION 1: I was just looking at the Burger King- FL plans and I did not see any landscaping plans listed on the cover sheet of the plans. Am I missing something or is there no landscaping involved on this job?

ANSWER 1: One can not determine the specific content of the Project by looking at the Sheet Index; suggest you review the Plans & Specs.

QUESTION 2: Who is responsible for installing the seating concept package? General Contractor or AAFES?

ANSWER 2: Sheet SC1.1, Furniture Schedule, Install (C) Contractor.

QUESTION 3: I was not able to locate the stucco/dryvit section in the specifications book. Please advise.

ANSWER 3: Sections 09201 Furring & lathing & 09220 Portland Cement Plaster (Stucco for exterior surfaces); there is no Dryvit on this Project

QUESTION 4: What is the scope of work for the mold removal? For estimating purposes are we responsible for all visible mold only? or Are we responsible for mold abatement on all walls throughout the facility i.e.. behind kitchen ceramic tiles/bathroom tiles, and or behind dining room wainscoting? If we are only responsible for visible mold, will all other issues be addressed by change orders?

ANSWER 4:

1. Section 01011 – Summary of Project, 1.1 Statement of Work, C. 1. Contractor shall secure and pay for the services of a fully licensed Mold Remediation Contractor to remove and clean the building of contaminates as listed in the accompanying document, Appendix D, before general construction begins.
2. Appendix D: Mold Survey Report & Protocol, page 12, Recommendation: “Based on the above findings, we conclude that Level III remediation be conducted throughout the facility...”

DRAWINGS AND SPECIFICITATIONS REVISIONS

The following revisions modify and/ or extend the drawings dated 15 April 2009 – Issue for Construction, prepared by SHER DYE & ASSOCIATES.

- 1. Plans – Revised 04 JUNE 09: (All Revised Drawings Incl #1 on website)**
 - a. **Sheet A0**
 - b. **Sheet A0.2**
 - c. **Sheet A1.1**
 - d. **Sheet A1.2**
 - e. **Sheet A1.5**
 - f. **Sheet A1.7**
 - g. **Sheet A2.0**
 - h. **Sheet A4.5**
 - i. **Sheet A4.6**
 - j. **Sheet A4.7**
 - k. **Sheet A4.9**
 - l. **Sheet A4.10**
 - m. **Sheet A5.0**
 - n. **Sheet A5.1**
 - o. **Sheet A6.1**
 - p. **Sheet A8.1**
 - q. **Sheet SC1.1**

- 2. Plans – Added Sheets 04 JUNE 09:**
 - a. **Sheet A5.2**
 - b. **Sheet S0.1**
 - c. **Sheet S1.1**
 - d. **Sheet S2.1**
 - e. **Sheet S2.2**

- 3. Specifications – Added Sections 04 JUNE 09 (All Revised Specifications Incl #2 on website)**
 - a. **03100 Concrete Formwork**
 - b. **03200 Concrete Reinforcement**
 - c. **05120 Structural Steel**
 - d. **06112 Framing and Sheathing**

- 4. Specification – Remove and Replace Sections 04 JUNE 09**
 - a. **Remove existing 00 TOC 2839**
 - b. **Replace with 00 TOC 2839 6-04-09**
 - c. **Remove existing 03300 Concrete for Buildings**
 - d. **Replace with 03300 Cast in Place Concrete**