

SECTION I

Instructions to Offerors --- Amendment of Solicitation. The following instructions apply unless specified otherwise in an AAFES letter accompanying this amendment.

a. Offerors must acknowledge receipt of this amendment prior to the hour and date specified for receipt of proposals in the original solicitation, or the hour and date specified in this amendment if such has been amended. Offeror must acknowledge by one of the following means:

(1) By signing and returning all except one copy of this amendment;

(2) By acknowledging receipt of this amendment on each copy of the proposal submitted;

(3) By separate letter or telegram which includes a reference to the solicitation and amendment number.

b. Proposals must be based upon and refer to the solicitation as amended. Unless an acknowledgment of this amendment is received by the Contracting Officer before the hour and date specified for receipt of proposals, Offeror's proposal may be considered nonresponsive.

c. If you desire to revise a proposal previously submitted, such revision must be received prior to the hour and date specified for receipt of proposals inclosed in a sealed envelope addressed to the issuing office, with the name and address of offeror and the solicitation number on the face of the envelope. Telegraphic proposals will not be considered unless authorized by the solicitation; however, proposals may be modified by telegraphic notice provided such notice is received prior to the time set for receipt of proposals. Telegraphic modifications should not reveal the amount of the original or of the revised proposal.

SECTION II

Instructions to Contractor --- Amendment of Contract.

Unless otherwise instructed, all except one copy of this Amendment are to be executed by a person authorized to bind the firm contractually and returned to the Contracting Officer. The effective date will be the date the amendment is signed in block 6 by the Contracting Officer or the date(s) indicated in block 4, whichever is later.

1. QUESTION: Is there a plant list or landscape specification?

ANSWER: No. There is no new plant material for this job. Please disregard note "02.03N – Landscaping" on sheet A0.2.

2. QUESTION: On A0.2 – What is 9.06N? (in conjunction with Clearance Sign Pole)

ANSWER: 09.06N is incorrect. It should be 02.19N – Paint Color S.W. #1812, "Award Blue". The existing sign is to remain.

3. QUESTION: On A1.2 – The "J" window in the office is shown as new, but is not shown as being removed on A1.1. Is it existing or replaced?

ANSWER: The J window is an existing window to remain, please refer to the window schedule on sheet A6.1.

4. QUESTION: On A1.2 – 12.01E indicates drink station cabinet is existing but references stainless steel and laminate finishes. Are we to replace the finishes of this existing cabinet?

ANSWER: We are replacing the finishes on the cabinet doors only. Please refer to the Interior Elevations (Drawing 1) on sheet A2.0.

5. QUESTION: On sheet A1.7 (Rev. Add-1), key note 07.21 calls for "new single ply roof to match existing", note 07.41 states existing as "built-up roof". These two systems are not compatible, meaning that single ply cannot be tied-in or spliced to built up, please advise. Also, I could not find any spec's for the new roofing system.

ANSWER: The existing roof, (not under warranty), is a single ply roof.

6. QUESTION: Also, I could not find any spec's for the new roofing system.

ANSWER: The manufacture of the single ply roofing is unknown; key note 07.21 calls for "new single ply roof to match existing."